

**51.038 DIRECT CONNECTION REQUIRED.**

At the time a public sewer becomes available to a property serviced by a private wastewater disposal system, a direct connection shall be made to the public sewer within 365 days in compliance with this chapter, and within 365 days any septic tanks, cesspools and similar private wastewater disposal systems shall be cleaned of sludge. The bottom shall be broken to permit drainage, and the tank or pit filled or may be removed.

Penalty, see ' 51.999