

51.060 CONFORMANCE TO STATE BUILDING AND PLUMBING CODE REQUIREMENTS.

(A) The size, slopes, alignment, materials of construction of building sewers and the methods to be used in excavating, placing of the pipe, jointing, testing, and backfilling of the trench, shall all conform to the requirements of the State Building and Plumbing Code or other applicable rules and regulations of the city. Cast iron pipe shall be used for a building sewer laid within 50 feet of any well per Minnesota Public Health department requirements.

(B) The connection of the building sewer into the public sewer shall conform to the requirements of the State Building and Plumbing Code or other applicable rules and regulations of the city. All connections shall be made gastight and watertight, and verified by proper testing to prevent the inclusion of infiltration/inflow. Any deviation from the prescribed procedures and materials must be approved by the city prior to installation.

Penalty, see ' 51.999